



later derivative models

165 Main Street
Cortland, NY 13045

Telephone 607-758-6286
Facsimile 607-758-6274
www.intertek.com

February 8, 2012

Mr. Luca Rappini
F.M.B. S.p.A
Via Turati, 16
40010 Sala Bolognese (BO)
ITALY

Re: **Union, Sovrana, Firbimatic and Realstar Models:** HC7-15-CS, HC7-15-CL, HC8-15-CS, HC8-15-CL, HC7-18-CS, HC7-18-CL, HC7-18-CLM, HC8-18-CS, HC8-18-CL, HC8-18-CLM, HC7-20-CS, HC7-20-CL, HC8-20-CS, HC8-20-CL, HC7-25-CS, HC7-25-CL, HC7-25-CLM, HC8-25-CS, HC8-25-CL, HC8-25-CLM, HC7-32-CS, HC7-32-CL, HC8-32-CS, HC8-32-CL, HC7-40-CS, HC7-40-CL, HC7-40-CLM, HC8-40-CS, HC8-40-CL, HC8-40-CLM, TR8-20-CS

Dear Mr. Rappini:

You have requested the results of the Intertek testing of the safety features of the above dry cleaning machines related to Underwriters Laboratories (UL) Standard 664 (Commercial Dry Cleaning Machines – Type IV, 2003 or later edition), UL Standard 2208 (Solvent Distillation Units, 1996 or later edition) where applicable, and National Fire Protection Association (NFPA) Standard 32 (2007 or later edition). These machines were designed and manufactured for use with Class III-A or Class III-B dry cleaning solvents.

Specifically related to NFPA 32, Chapter 8 (Type III Dry Cleaning Plants) and Sections 8.1.2.4, 8.1.2.6, 8.1.3.3, and 8.1.3.4 all of the above dry cleaning machines include one or more of the safety features in those sections. As a result of the dry cleaning machines meeting one or more of the safety features, the dry cleaning machines are permitted by NFPA 32 to be used in dry cleaning plants that do not have a sprinkler system, that are ordinary (unclassified) electrical locations as defined in NFPA 70, National Electric Code, and that are separated from other occupancies in the building or adjoining buildings by construction having at least a one-hour fire resistance rating.

Please note that the dry cleaning machines bear a name plate listing, among other information, the Intertek certification Mark (ETL), the standards under which the machines were tested and the type(s) of solvent permitted for use in the machines.

This letter may be reproduced for any lawful purpose, provided it is reproduced in its entirety.

Very truly yours,

William T. Fiske
Senior Director – Technical Affairs
Intertek C & E West

